



## Pipe or Tubing Support Span Calculations

Client:	Description:	Prepared By:	Approval:	Date:	Rev.:
					0
Customer No.:	Item No.:				1
					2
Owner No.:	Dwg. No.:				3
					4

The user is responsible for verifying that method and results are correct.

Service:	new process	SG =	1.00	Measurement Units:	Imperial
Design Temperature:	<input checked="" type="radio"/> F <input type="radio"/> C	100	Deg. F	Corrosion, erosion, mech. allow:	C = 0.0000 inch
Factor of Safety:	FS =	4.0		Ice Thickness (external):	T <sub>ice</sub> = 0 inch
<b>Pipe or Tubing Material:</b>			<b>Pipe or Tube Dimensions:</b>		
ASTM A 53-B Type S Carbon Steel Pipe			Nom. Size: NPS 8 (DN 200)		
Hot modulus of elasticity E = 2.934E+07 psi			Nom. Thk.: Sch 40 per ASME B36.10M		
Hot allowable stress S <sub>h</sub> = 20,000 psi			Actual OD: D <sub>o</sub> = 8.625 inch		
Design stress, Sh / FS S <sub>a</sub> = 5,000 psi			Nominal thickness: T <sub>nom</sub> = 0.322 inch		
Material density P <sub>den</sub> = 2.833E-01 lb/in <sup>3</sup>			Thickness tolerance: Mill = 12.5% and, h = 0.000 inch		
Relative weight factor (vs. carbon steel) Mat = 1.000					
<b>Insulation:</b> Semi-rigid Fiberglass			<b>Liner on ID:</b> none		
Density, I <sub>ns</sub> = 7.0 lb/ft <sup>3</sup>			L <sub>den</sub> = 0.000E+00 lb/in <sup>3</sup>		
Thk, T <sub>i</sub> = 2 inch			I <sub>den</sub> = 4.051E-03 lb/in <sup>3</sup>		
Comments: x			<b>Weight of concentrated load assumed at center of span (valves + flanges + animal, etc.):</b>		
x			W <sub>c</sub> = 0 lbs		
x					
Minimum pipe thickness, t = T <sub>nom</sub> - (T <sub>nom</sub> * Mill % / 100) - c - h				t = 0.3216 inch	
Outside radius of pipe, R = D <sub>o</sub> / 2				R = 4.313 inch	
Pipe moment of inertia (based on t), I = π / 64 [ D <sub>o</sub> <sup>4</sup> - (D <sub>o</sub> - 2t) <sup>4</sup> ]				I = 7.241E+01 in <sup>4</sup>	
Pipe inside diameter, d = D <sub>o</sub> - 2 T <sub>nom</sub>				d = 7.981 inch	
Pipe section modulus, Z = π / 32 (D <sub>o</sub> <sup>4</sup> - d <sup>4</sup> ) / D <sub>o</sub>				Z = 1.681E+01 in <sup>3</sup>	
Metal area of pipe cross-section, A <sub>m</sub> = (D <sub>o</sub> <sup>2</sup> - d <sup>2</sup> ) * π / 4				A <sub>m</sub> = 8.40 in <sup>2</sup>	
Conversion factor, water density, d <sub>w</sub> = 62.4 lb / cu ft				d <sub>w</sub> = 62.40 lb/ft <sup>3</sup>	
Conversion factor: n = 1 ft / 12 in				n = 8.3333E-02 ft / in	
Pipe weight per unit length, W <sub>p</sub> = P <sub>den</sub> * A <sub>m</sub> / n				W <sub>p</sub> = 28.55 lb / ft	
Pipe or liner or refractory inside diameter, d <sub>L</sub> = d - 2 T <sub>r</sub>				d <sub>L</sub> = 7.981 inch	
Liner area cross-section, A <sub>r</sub> = (d <sup>2</sup> - d <sub>L</sub> <sup>2</sup> ) * π / 4				A <sub>r</sub> = 0.00 in <sup>2</sup>	
Liner weight per unit length, W <sub>r</sub> = L <sub>den</sub> * A <sub>r</sub> / n				W <sub>r</sub> = 0.00 lb / ft	
Flow area, A <sub>f</sub> = d * L <sup>2</sup> * π / 4				A <sub>f</sub> = 5.003E+01 in <sup>2</sup>	
Fluid weight per unit length, W <sub>f</sub> = SG * A <sub>f</sub> * n <sup>2</sup> * d <sub>w</sub>				W <sub>f</sub> = 21.68 lb / ft	
Insulation outside diameter, D <sub>io</sub> = D <sub>o</sub> + 2 T <sub>i</sub>				D <sub>io</sub> = 12.63 inch	
Insulation area cross-section, A <sub>i</sub> = (D <sub>io</sub> <sup>2</sup> - D <sub>o</sub> <sup>2</sup> ) * π / 4				A <sub>i</sub> = 66.76 in <sup>2</sup>	
Insulation weight per unit length (w/ factor 1.12 for lagging), W <sub>i</sub> = 1.12 * A <sub>i</sub> * n <sup>2</sup> * I <sub>ns</sub>				W <sub>i</sub> = 3.63 lb / ft	
Ice area cross-section, A <sub>ice</sub> = [ (D <sub>io</sub> + (2 * T <sub>ice</sub> )) <sup>2</sup> - D <sub>io</sub> <sup>2</sup> ] * π / 4				A <sub>ice</sub> = 0.00 in <sup>2</sup>	
Ice weight (external w/ S.G. = 0.9) per unit length, W <sub>ice</sub> = 0.9 * A <sub>ice</sub> * n <sup>2</sup> * d <sub>w</sub>				W <sub>ice</sub> = 0.00 lb / ft	
<b>Total weight per unit length, W = W<sub>p</sub> + W<sub>r</sub> + W<sub>f</sub> + W<sub>i</sub> + W<sub>ice</sub> (excluding W<sub>c</sub>)</b>				<b>W = 53.87 lb / ft</b>	

Method ( A ) -- Reference book <i>Design Of Piping Systems, pp. 239 - 240 &amp; 356 - 358, by M. W. Kellogg, Second Edition, 1956</i>	
Type of support span	Single span, free ends <input type="text" value="32.00"/>
Length of support span	L = 32.00 feet
Factor for modifying stress value obtained by the basic formula for S	fs = 1.250
Maximum calculated bending stress due to loads, $S = fs ( 1.2 W L^2 / Z ) ( 2 W_c / W L )$	S = 4,922.3 psi
The calculated bending stress is within limits.	
Factor for modifying deflection value obtained by the basic formula for y	fy = 1.316
Deflection, $y = fy ( 17.1 ( W L^4 / E * I ) )$	y = 0.598 inch
Natural frequency estimate, $fn = 3.13 / y^{0.5}$	fn = 4.046 Hz
OK. Natural frequency above 4 Hz is recommended for most spans. Consider 8 Hz or more for pulsating line.	
Slope of pipe between supports for drainage, $h = ( 12 * L )^2 * y / ( 0.25 ( 12 * L )^2 - y^2 )$	h = 2.393 inch
Method ( B ) -- Reference Book: <i>Piping Handbook, pg 22-47, by Crocker and King, Fifth Edition, 1967, McGraw-Hill</i>	
Length of support span (Single Span w/ Free Ends)	 <input type="text" value="32.00"/>
Maximum bending stress, $Sw_1 = ( 0.75 W * (L_1)^2 + 1.5 W_c * L_1 ) * D_o / I$	Sw <sub>1</sub> = 4,927.8 psi
Deflection, $y_1 = ( 22.5 W * (L_1)^4 + 36 W_c * (L_1)^3 ) / ( E * I )$	y <sub>1</sub> = 0.598 inch
The calculated bending stress is within limits. Deflection is within recommended limits.	
Natural frequency estimate, $fn_1 = 3.13 / ( y_1 )^{0.5}$	fn <sub>1</sub> = 4.047 Hz
OK. Natural frequency above 4 Hz is recommended for most spans. Consider 8 Hz or more for pulsating line.	
Slope between supports for drainage, $h_1 = ( 12 * L_1 )^2 * y_1 / ( 0.25 ( 12 * L_1 )^2 - (y_1)^2 )$	h <sub>1</sub> = 2.393 inch
Length of support span (Continuous Straight Run)	 <input type="text" value="39.00"/>
Maximum bending stress, $Sw_2 = ( 0.5 W * L_2^2 + 0.75 W_c * L_2 ) * D_o / I$	Sw <sub>2</sub> = 4,879.7 psi
Deflection, $y_2 = ( 4.5 W * (L_2)^4 + 9 W_c * (L_2)^3 ) / ( E * I )$	y <sub>2</sub> = 0.264 inch
The calculated bending stress is within limits. Deflection is within recommended limits.	
Natural frequency estimate, $fn_2 = 3.13 / ( y_2 )^{0.5}$	fn <sub>2</sub> = 6.092 Hz
OK. Natural frequency above 4 Hz is recommended for most spans. Consider 8 Hz or more for pulsating line.	
Slope between supports for drainage, $h_2 = ( 12 * L_2 )^2 * y_2 / ( 0.25 ( 12 * L_2 )^2 - (y_2)^2 )$	h <sub>2</sub> = 1.056 inch